






REVISIONS			
REV.	DESCRIPTION	DATE	APPROVED
A			



- ① Control circuit wiring terminal AR AN BR BN (230V)
- ② Manual Operating Handle
- ③ Selection switch (Manual / Auto)
- ④ ON/OFF Indicator
- ⑤ Normal Source cable terminal
- ⑥ Auxiliary contact switch (ASW, BSW)
- ⑦ Emergency Source terminal
- ⑧ Load (Outgoing) cable terminal

FRONT VIEW

THIRD ANGLE PROJECTION



safety distance S1: $\geq 30\text{mm}$
S2: $\geq 240\text{mm}$

LEFT SIDE VIEW

W2H 63-125A dimensions

dimension poles	A	B
2P	146	59
3P	167	80
4P	188	101

NOTES:

1. FOR 2-POLE SWITCHES, OMIT CENTER POLE.
2. OPEN TYPE SWITCH SUPPLIED WITH SHOCK PROTECT PACKAGING IN BOX, OPTIONAL ATS CONTROLLER TO BE SUPPLIED SEPARATELY.
3. DO NOT RUN CABLES IN FRONT OF SWITCH. RUN ALL CABLES ON LEFT/RIGHT SIDES.
4. MAINTAIN ELECTRICAL CLEARANCE OF 1(25mm) MIN. BETWEEN LIVE METAL PARTS AND GROUNDED METAL.
5. ALL DIMENSIONS ARE FOR REFERENCE ONLY AND SHOWN IN MILLIMETERS.
6. SEE OPTIONAL "ATS CONTROLLER" & "ATS CONTROLLER" DIMENSIONS ON SHEET 2.

SIGNATURES		DATE
MODEL	DL	28/04/17
DETAIL		
CHECKED		
ENGRG	GL	28/04/17
MFG		
QUALITY		
ISSUED	AH	28/04/17

TITLE
AUTOMATIC TRANSFER SWITCH
63 - 125 A
W2H(OT)

DRAWING FILE: PTS-W2H-125-4P-5.dwg
MODEL / ASSEMBLY FILE: PTS-W2H 63-125A

SIZE B DWG NO W2H-125-4P-5-1


AutoCad Generated

CTQs DRIVING BUSINESS PERFORMANCE


SCALE: SHEET 1 of 3



REVISIONS			
REV.	DESCRIPTION	DATE	APPROVED
A			




WST-5 Controller FRONT VIEW



WST-5 Controller BACK VIEW

THIRD ANGLE PROJECTION




AutoCad Generated

SIGNATURES		DATE
MODEL	KL	23/03/20
DETAIL		
CHECKED		
ENGRG	KL	23/03/20
MFG		
QUALITY		
ISSUED	KL	23/03/20
DRAWING FILE: PTS-W2H-125-4P-5.dwg		SIZE B
MODEL / ASSEMBLY FILE: PTS-W2H 63-125A		DWG NO
# CTQs	DRIVING BUSINESS PERFORMANCE	SCALE:

TITLE	
AUTOMATIC TRANSFER SWITCH 63 - 125 A W2H(OT)	
SIZE B	DWG NO W2H-125-4P-5-2
SHEET	2 of 3



REVISIONS			
REV.	DESCRIPTION	DATE	APPROVED
A			



Depending On Site Conditions (May No Need To Connect)

- Setting:-
 Password : 00318
 1. AC System : 3P4L
 2. Neutral Setting : 2>No Breaking
 3. Output 2 : 12>Gen Start Output (N/O)
 4. Output 3 : 24>ATS Power L1 (N/O)
 5. Output 4 : 27>ATS Power N (N/O)


W2H & WST-5 Wiring Diagram

SIGNATURES		DATE
MODEL	KL	23/03/20
DETAIL		
CHECKED		
ENGRG	KL	23/03/20
MFG		
QUALITY		
ISSUED	KL	23/03/20

AUTOMATIC TRANSFER SWITCH
 63 - 125 A
 W2H(OT)

DRAWING FILE: PTS-W2H-125-4P-5.dwg	SIZE	DWG NO
MODEL / ASSEMBLY FILE: PTS-W2H 63-125A	B	W2H-125-4P-5-3
# CTQs	SCALE:	SHEET

THIRD ANGLE PROJECTION



AutoCad Generated

DRIVING BUSINESS PERFORMANCE

